

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO: 108/25-26

Dated : 28/10/25

It is certified that an inspection team headed by Pediatrician, CHN Nuggehalli

(Name of officers with designation) from CHC Nuggehalli PHED

Inspected the KOTEMANE INTERNATIONAL SCHOOL, HONNAMARANAGHALLI

(Name and Address of the school) on 28/10/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no RDWS & SD / F11PNO666 / WQMSP / 2025-26/673 Dated 1/8/25

Of Executive engineer, Rural drinking water and sanitation Department, Hassan (PHED Lab) certified that the

KOTEMANE INTERNATIONAL SCHOOL (Name of school) has safe drinking water

Facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the central/ State/ U.T. Govt.

This certificate is valid till 28/10/2026

Signature with Seal:

Name : Dr. Raghavendra M

Designation : Pediatrician, CHN Nuggehalli

Name and Address of the office Department :

Administrative Medical Officer

Community Health Centre

Nuggehalli Channarayapatna (T)

Hassn (D) -573131

To,

Principal


Kotemane International School

Honnamaranahalli, Nuggehalli (H)

Channarayapatna (T) Hassan (D)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Shay
TRUE COPY
Attested Compared
with Original

03 NOV 2025.

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 108/25-26

Dated: 28/10/25

It is certified that an inspection team headed by ... PEDIATRICIAN, CHC NUGEHALLI

(Name of Officers with designation) from ... CHC NUGEHALLI PHED

inspected the ... Kotemane International school, Honnomanahalli

(Name & Address of the school) on 28/10/25 (date of inspection) and on the basis of
RDWCL SD/FIPN0666/WQMSPL/2025-26/673

Water Test Report (Attached) bearing no. dated 18/10/25

of 01 Executive engineer, Rural drinking water & sanitation department, Hallur
of Kotemane International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 28/10/2026

M. Dabbale 28/10/25

Signature with Seal: ...

Name

Dr. Radhika M. Dabbale

Designation

PEDIATRICIAN, CHC NUGEHALLI

Name & Address of the Office/ Department

RDWCL SD/FIPN0666/WQMSPL/2025-26/673

To

Principal

Kotemane International school

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



GOVERNMENT OF KARNATAKA
O/o Executive Engineer, Rural Drinking Water & Sanitation Department,
Hassan Division Hassan.

Phone No.08172-261640

Email Id:eerdwsd.hsn@gmail.com

RDWS&SD/File No 666/WQMSP/2025-26 / 673

Date: 01/08/2025

To,
The Principal
Kotemane international Trust,
Honnamaranahalli Village,
Nuggehalli Hobli,
Channarayapatna Taluk,
Hassan District..

Subject :- Regarding safe drinking water certificate.


Reference:- Your request letter for safe drinking water certificate

Dated:24.07.2025.


As per your request, the bore well water sample submitted from Kotemane International School has been tested in accordance with IS 10500:2012 standards. The analyzed values for the 16 parameters fall within the permissible limits as specified by IS 10500:2012. Hence, the bore well water is considered safe for drinking purposes. The detailed test report is attached for your reference

Encl: Test Report

Your Faithfully


Executive Engineer

Rural Drinking Water & Sanitation
Department Hassan Division


Hassan



**Rural Drinking Water and Sanitation Department
District Drinking Water Testing Laboratory, Hassan**

Office of the Executive Engineer, Rural
Drinking Water and Sanitation Department
Hassan Division, Hassan 573201

eerdwsd.hsn@gmail.com
rdwsd.wqmsp.hassanlab@gmail.com
Phone No.08172-261640


WATER SAMPLE TEST REPORT			
1. District	Hassan	5. Sample collection Date :	27.06.2025
2. Taluk	Channarayapattna	6. Sample received date :	27.06.2025
3. Village	Honnamaranahalli	7. Source :	Bore well
4. Grama panchayath :	Jamburu	8. Name and address:	Kotemanne International School, Mavinahalli Gate Honnamaranahalli Village, Nuggehalli Hobli, Channarayapattana Taluk, Hassan Dist.

Sl No.	Characteristic	Requirement (Acceptable limit)	Permissible Limit in the Absence of Alternate Source	Method of Test, Ref to	Result
1	Colour, Hazen units	5	15	IS 3025 (Part-4):2021	1
2	Odour	Agreeable	Agreeable	IS 3025 (Part-5 &6):2018	Agreeable
3	Taste	Agreeable	Agreeable	IS 3025 (Part-8):1983(RA 2017)	Agreeable
4	Ph, Value	6.5-8.5	No Relaxation	IS 3025 (Part-11): 2022	7.78
5	Turbidity, NTU	1	58	IS 3025 (Part-10): 2023	1
6	Total Dissolved solid, mg/l	500	2000	IS 3025 (Part-16): 2023	180
7	Conductivity us/cm	-	-	IS 3025 (Part-14): 2019	274.2
8	Calcium (as Ca) mg/l	75	200	IS 3025 (Part-40): 2024	14.42
9	Chloride (as Cl)mg/l	250	1000	IS 3025 (Part-32): 1988	15.99
10	Fluoride (as F)mg/l	1	1.5	APHA 24 th Edition : 4500 F-D	0.11
11	Iron (as Fe) mg/l	1	No Relaxation	IS 3025 (Part-53): 2024	<0.10
12	Magnesium (as Mg) mg/l	30	100	IS 3025 (Part-46): 2023	5.83
13	Nitrate (as NO ₃) mg/l	45	No Relaxation	APHA 24 th Edition : 4500 NO ₃ -B	3.4
14	Sulphate (as SO ₄) mg/l	200	400	IS 3025 (Part-24/sec 1) : 2022	7.1
15	Total Alkalinity mg/l	200	600	IS 3025 (Part-23): 2023	88
16	Total Hardness (as CaCO) mg/l	200	600	IS 3025 (Part-21): 2009	60.54

Inference : The analyzed values for the above parameters are within the limit as per IS-10500:2021.

Date : 30.06.2025

Place : Hassan



S. Jayanna
S. JAYANNA
B.Sc, M.A, I.L.B.,
Advocate & Notary

3rd Main Road, K. R. Extension,
TIPUR - 572201, Tumkur Dist.
Karnataka
Mob : 9448979547, 8310055736

Chemist
District Water Testing Laboratory
R.D.W & S D Hassan.

This paper is translated from Kannada to English



ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ಸ್ವೇಚ್ಚಾಲ್ಯಾ ಇಲಾಖೆ
ಚಿಲ್ಡ್ ಕುಡಿಯುವ ನೀರು ಪರೀಕ್ಷೆ ಪ್ರಯೋಗಾಲಯ, ಹಾಸನ

ಕಾರ್ಯಕ್ರಾಂತಿಕ ಅಧಿಕಾರಿ ಅಧಿಕಾರಿ ಕೆ.ಎಂ. ಗ್ರಾಮೀಣ
ಕುಡಿಯುವ ನೀರು ಮತ್ತು ಸ್ವೇಚ್ಚಾಲ್ಯಾ ಇಲಾಖೆ,
ಹಾಸನ ವಿಧಾನ, ಹಾಸನ 573201

eerdwsd.hsn@gmail.com
rdwsd.wqmsp.hassanlab@gmail.com
Phone No.08172-261640

WATER SAMPLE TEST REPORT

1.District :	Hassan	5.Sample collection date:	27.06.2025
2.Taluk:	Channarayapattana	6.Sample received date:	27.06.2025
3.Village:	Honnamaranahalli	7.Source:	Bore well
4.:Grama Panchayath:	Jamburu	8.Name and address:	Kotemane International School, Mavinahalli Gate, Honnamaranahalli Village, Nuggehalli Hobli, Channarayapattana Taluk, Hassan.

Sl.No	Characteristic	Requirement (Acceptable limit)	Permissible Limit in the Absence of Alternate Source	Method of Test,Ref to	Result
1	Colour,Hazen units	5	15	IS 3025(Part-4):2021	1
2	Odour	Agreeable	Agreeable	IS 3025(Part -5 &6):2018	Agreeable
3	Taste	Agreeable	Agreeable	IS 3025 (Part-8):1983 (RA 2017)	Agreeable
4	Ph, Value	6.5-8.5	No Relaxation	IS 3025 (Part-11):2022	7.78 ✓
5	Turbidity, NTU	1	5	IS 3025 (Part -10):2023	1
6	Total Dissolved solid, mg/l	500	2000	IS 3025 (Part -16):2023	180 ✓
7	Conductivity us/cm	-	-	IS 3025 (Part -14):2019	274.2
8	Calcium(as Ca) mg/l	75	200	IS 3025 (Part- 40):2024	14.42 ✓
9	Chloride (as Cl) mg/l	250	1000	IS 3025 (Part -32):1988	15.99 ✓
10	Fluoride (as F)mg/l	1	1.5	APHA 24th Edition:4500 F-D	0.11 ✓
11	Iron (as Fe)mg/l	1	No Relaxation	IS 3025 (Part -53):2024	<0.10 ✓
12	Magnesium (as Mg) mg/l	30	100	IS 3025 (Part -46):2023	5.83 ✓
13	Nitrate (as NO ₃) mg/l	45	No Relaxation	APHA 24th Edition:4500 NO ₃ -B	3.4 ✓
14	Sulphate (as SO ₄) mg/l	200	400	IS 3025 (Part -24/sec 1):2022	7.1 ✓
15	Total Alkalinity mg/l	200	600	IS 3025 (Part -23):2023	88 ✓
16	Total Hardness (as CaCO ₃)mg/l	200	600	IS 3025 (Part -21):2009	60.54 ✓

Inference: The analyzed values for the above parameters are within the limit as per IS-10500:2012.

Date:30.06.2025

Place: Hassan

Praveen C. C.
Chemist
District Water Testing Laboratory
R.D.W. & S.D Hassan.

